

# MUNICIPAL CORPORATION JALANDHAR

## WATER TESTING LABORATORY

(WATER ANALYSIS REPORT)

REF. NO:- 538 SAMPLE PROVIDED BY:- Delhi Public School  
G.T. Road, Jalandhar Cantt.

REF. DT. 28/12/20 SAMPLE COLLECTED:-

SR. NO.	TEST	REQUIRED LIMIT IS10500	SAMPLE (1)	SAMPLE (2)	SAMPLE (3)	SAMPLE (4)
1	COLOUR	5 HAZEN	Colourless			
2	ODOUR	UNOBJECTIONABLE	Odourless			
3	TASTE	AGREEABLE	Tasteless			
4	PH	6.5-8.5	6.8			
5	TOTAL HARDNESS AS CaCO <sub>3</sub>	300 mg/l	210			
6	DISSOLVED SOLIDS(TDS)	500 ppm	320			
7	ALKALINITY	200 mg/l	180			
8	CALCIUM AS Ca <sup>++</sup>	75 mg/l	30.0			
9	IRON	0.3 mg/l	0.1			
10	CHLORIDE	250 mg/l	110.0			
11	SULPHATE	150 mg/l	-			
12	NITRATES	4.5 mg/l	0.4			
13	RESIDUAL CHLORINE	0.2 mg/l	0.0			
14	FLUORIDE	1.0 mg/l	0.2			
15	LEAD	0.05 mg/l	-			
	BACTERIAL TEST		/			
	TOTAL COLIFORM COUNT BY MPN METHOD PER 100ML		ND			
	TOTAL E-COLI COUNT BY MPN METHOD PER 100ML		/			

REMARKS:-

The provided water sample's test report is satisfactory as of applied tests.



  
 Analyst  
 Municipal Corporation  
 Jalandhar 30/12/20