

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY
(WATER ANALYSIS REPORT)

REF. NO: -1709

REF. DATE: -21/07/26

Sample provided by :- Delhi Public School, G.T. Road, Jalandhar Cantt., Jalandhar city

SR.NO	TEST	REQUIRED LIMIT IS10500	SAMPLE
1	COLOUR	5 Hazen	Colorless
2	ODOUR	Unobjectionable	Normal
3	TASTE	Agreeable	normal
4	PH	6.5 – 8.5	6.8
5	DISSOLVED SOLIDS (TDS)	500 ppm	156
6	TOTAL HARDNESS (as CaCO ₃)	300 mg/l	80
7	ALKALINITY	200 mg/l	70
8	CALCIUM (as Ca++)	75 mg/l	8.6
9	IRON	0.3 mg/l	0.1
10	CHLORIDE	250 mg/l	26.0
11	SULPHATES	150 mg/l	nil
12	NITRATES	4.5 mg/l	nil
13	FLUORIDE	1.0 mg/l	0.1
14	RESIDUAL CHLORINE	0.2 mg/l	nil
15	TOTAL COLIFORM COUNT (by MPN method per 100ml)	✓ NIL	nil

REMARKS :-

Provided water sample found satisfactory as per applied tests



DATE: -23/07/26

Neeraj Kumar
Analyst
ANALYST
MUNICIPAL CORPORATION JALANDHAR